

LAKE HAVASU UNIFIED SCHOOL DISTRICT #1

AGENDA ACTION ITEM

TOPIC: APPROVAL TO REPLACE HVAC MECHANICAL UNITS
AT LAKE HAVASU HIGH SCHOOL

SUBMITTED BY: Michael Murray, Director of Business Services
John Simpson, Maintenance Supervisor

DATE FOR BOARD CONSIDERATION: June 20, 2017

RECOMMENDATION:

It is recommended that the Governing Board approve replacement of air conditioning units at Lake Havasu High School, by Pueblo Mechanical, at an amount not to exceed \$38,000.00.

RATIONALE:

On May 5, 2017, the local utility provider experienced a line loss that caused a significant power decrease at Lake Havasu High School. Several HVAC units in areas surrounding the new gym quit working, and it has been determined that replacement of the units is required.

A request for quotations was issued to two local firms and to Pueblo Mechanical. Pueblo did submit the lowest quotation at \$36,946.36, although an approval amount of \$38,000.00 is requested to cover incidentals. Backup is attached for your reference.

The purchase will be made through MESC (Mohave Educational Services Cooperative) Contract #14G-PMAC2-0903. A claim for the incident that occurred on May 5 has already been filed with the District's insurer, The Trust, and the purchase order and invoice for the HVAC replacement will be submitted under that claim.

This item has been reviewed and approved by the Purchasing department.

Approved for Transmittal to Governing Board _____
Superintendent